

- 1. Members are responsible for supplying and installing entire assembled meter loop on FEC Pole. FEC is to be notified when loop is ready for inspection.
- 2. Meter loop must pass inspection before service is connected.
- Line and Load conductors cannot be installed in the same riser.
 Load conductors supplying overhead feeders must be in a separate riser.

DATE: 3/20/2025



Single Phase Transformer Pole -

1Ø 60-200 Amp Meter Loop on Transformer Pole. Voltages: 120/240

Phone

(979) 968-3181 1-866-968-3181

MS-20