



***ALL work Shall be installed in a neat and workman-like manner per NEC 110.12**

FEC has the authority of interpretation of "neat and workman-like manner" based on our experiences or precedents as the basis of our judgements.

*Contact Co-op for Conductor Sizing

Riser Diameter Size will depend on Service and Conductor Size
 Riser Length:
 Dependent on Pole Height
 40 ft Pole = 17 ft Conduit Riser
 45 ft Pole = 20 ft Conduit Riser

Notes:

1. Disconnect must pass inspection before service is connected.
2. #6 Solid bare copper wire to be bonded to FEC Pole ground.

Schedule 40 PVC is allowed below finished grade
 Must be minimum 24" Deep

DATE: 3/20/2025



**Three Phase Fused Disconnect
 - on Transformer Pole - Voltage: 480**

Phone	(979) 968-3181 1-866-968-3181	MS-62
--------------	--------------------------------------	--------------